

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/32

No.F.6/DFS/MS/School/2022/NDZ/ 489

Dated: 06/05/2022

FIRE SAFETY CERTIFICATE

Certified that the Greenfields Public School at D Block, Vivek Vihar, Delhi-110095, comprised of Ground & One Upper Floor owned / occupied by Greenfields Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/NDZ/509 dated 12/03/2019. The premises was re-inspected by the officer concerned of Fire Service on 29/04/2022 in the presence of Smt. Namita Joshi (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular letter No. 3298-3398 dated 01/03/2011 issued by Director of Education and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 06/05/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 06/05/2022 at New Delhi by


06/05/22

(Dr. S.K. TOMAR)

DY. CHIEF FIRE OFFICER.

Copy to :-

1. The Principal, Greenfields Public School, D Block, Vivek Vihar, Delhi-110095.
2. The Joint Director of Education, (Land & Estate), Lucknow Road, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

N/16
INSPECTION REPORT

1. Name & address of the building: Greenfields Public School at D Block, Vivek Vihar, Delhi-110095.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground & One Upper Floors only
4. Type of Case : Renewal
5. Details of previous NOC No. : F6/DFS/MS/School/2019/NDZ/509 dated 12/03/2019
6. Fire Safety directives Letter No. : Circular letter No. 3298-3398 dated 1/03/2011
7. Date of inspection : 29/04/2022
8. Name of the Inspecting Officer : D.O. (East)
9. Name and designation of Officer from the building side : Smt. Namita Joshi (Principal)
10. Year of Construction : 1975
11. Applicant's letter received through : email dated 12/04/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Old Cir dated 1/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	5.50m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50m	1.25m each	MR (Old Case)
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	NA	NA	NA
	c. Width Of Corridor	1.5m	2.4m & 3.1m	MR
	d. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	25	MR
	• Types	ABC /Co2	ABC / Co2	MR
	• ISI marking	ISI Marked	ISI Marked	MR

OK

1/17

6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	2	NA
	• Length of hose reel hose	NA	30m	NA
	• Nozzle diameter	NA	5mm	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	450LPM	NA
	➤ Head of the pump	NA	40m	NA
	➤ Power supply	NA	Provided	NA
	➤ Auto starting of pump	NA	Provided	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	5000 Liters	NA




Handwritten signature or initials.


P/18


		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2019/NDZ/509 dated 12/03/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : Divisional Officer (East)



Dy. CEO (NDZ)

 01/5/22

Dy. CEO (NDZ) As Approved, F.T. is added for sign.

Dy. CFO (NDZ)

 01/5/22


 06/5/22

MS